

From

The Head
Department of Microbiology
PAU, Ludhiana.

To

Guru Nanak Dev Public Sen. Sec. School
Ghunes
Barnala

Memo. No. 2668

Dated: 26-04-2024

Subject: Bacteriological quality of drinking water (IS-10500:1991. BIS New Delhi).

Reference is made to your letter No. nil dated 23.04.2024 regarding sample bacteriological analysis.

REPORT

S. No.	Source	Coliform organisms		Faecal Coliform / Detected / Not de
		Present/ Absent	Most Probable Number index (<10/100ml)	
01	Water Sample	Present	1100	Detected

INFERENCE

Bacteriologically safe :- nil

*Bacteriologically not safe :- 01

Amandeep Singh
Technician
Water Testing Lab
Department of Microbiology
PAU, Ludhiana

Biney Lal Singh
Principal
Guru Nanak Dev Public Sr. Sec. School
GHUNAS (BARNALA) ID No. 1631199

[Signature]
26/4/24
Incharge
Water Testing Lab
Department of Microbiol
PAU, Ludhiana

NOTE: This result relates to the sample provided to us and laboratory is not responsible for drawing/collecting of samples. The contents of this report are meant for your guidance and should not be used for Advertisement, Evidence and Litigation. This test document shall not be reproduced without the permission of the University.

[Signature]
Secretary/Manager
School Management Committee
Guru Nanak Dev Public Sen Sec School,
Ghunas

[Signature]
26/4/24
Head
Department of Microbiol

*Treatment for non-potable water as per WHO recommendations: Treat 20L of water with 10% Sodium hypochlorite or 1.8mL dose of 5% Sodium hypochlorite solutions with retention time of 30 Mins. The water must be used within 24 hours of treatment. The solution is available at the chemical stores.

Performa regarding sanitary condition certificate

No. 973

Date 29/04/2024


It is certified that an inspection team headed by Ranjeet Kumar MPSCM? (name of officer with designation) from Sub Divisional Hospital Tapa (name of department / office)

Inspected the Guru Nanak Dev Public Sen. Sec. School Ghunas (name and address of the School) on 19/4 and


Found that the Guru Nanak Dev Public Sen. Sec. School Ghunas, 2024 (name of the school)


Is maintaining the hygienic sanitation condition in the school building and campus as per the norms prescribed by central/state/UT government.

The above valid for a period of one year


Signature with seal Senior Medical Officer
H.C. J.D.H. TAPA
Name: Dr. Naveet Pal Singh
Designation: S.M.O.

To
Guru Nanak Dev
Public ~~School~~ Sen. Sec.
School Ghunas
(Name and address of the institution)


Principal
Guru Nanak Dev Public Sr. Sec. School
GHUNAS (BARNALA) ID No. 1631199


Secretary Manager
School Management Committee
Guru Nanak Dev Public Sen Sec School
Ghunus